

DOCUMENT 00 00 16

ADDENDUM NO. 6
JUNE 21, 2023

2023 CONSTRUCT SRE BUILDING
AIP No. 3-27-0025-19-2023
CITY OF DULUTH NO. 23-4402
SKY HARBOR AIRPORT
DULUTH, MN

SEH No. DULAI 167772

From: Short Elliott Hendrickson Inc.
3535 Vadnais Center Drive
St. Paul, MN 55110-3507
651.490.2000

To: Document Holders

DOCUMENT HOLDERS on the above-named project are hereby notified that this document shall be appended to, take precedence over and become part of the original bidding documents dated May 10, 2023 and Addenda dated May 22, 2023, May 31, 2023, June 2, 2023, June 16, 2023, and June 19, 2023 for this work. Bids submitted for the construction of this work shall conform to this document.

This addendum consists of 1 page.

Changes to Introductory Information: N/A

Changes to Specifications: N/A

Changes to Plan Drawings: N/A

Contractor Questions:

1. Geotechnical report indicated groundwater elevation to be at 592.00' and if excavation extend greater than 2-feet below, well points will likely be required for dewatering. Should contractors utilize groundwater elevation of 592.00 for bidding purposes? **No – Contractors shall utilize a hydrostatic groundwater elevation of 602.00', which is Lake/Harbor elevation, for dewatering and bidding purposes. Well points likely required based on hydrostatic groundwater elevation.**
2. Line-Item No. 9 & Section 31 41 40 – Structural Shoring (Temporary). What is the intent behind the item? Is certain shoring method required? **Intent is for the Contractor to provide necessary shoring methods to allow construction of the SRE building, foundation and footings while not disturbing the fence line and beyond. Means & methods are up to the Contractor to determine how to facilitate and complete this item in a safe and non-disturbing manner.**

Contractor Substitutions:

3. Panel substrate material from G-90 Galvanized to AZ-50/55. **This substitution is approved.**

Note: Receipt of this Addendum No. 6, dated June 21, 2023, shall be acknowledged on [Bid Express](#). Failure to do so will not allow Bidder to submit Bid.

END OF ADDENDUM